



NEECO II-Area 2, Inc.

AAA-Classified by National Electrification Administration
Mega Large Electric Cooperative – 10 Towns and 1 City

Headquarters: Maharlika Highway, Diversion,
San Leonardo, 3102 Nueva Ecija, Philippines
Main Phone Number: (044)-940-9040

July 2, 2026

SUPPLEMENTAL BULLETIN NO. 1

Dated (ITB No. 2026-06-03) June 14, 2026

TO : ALL REGISTERED BIDDERS

This Bid Bulletin is issued to modify and/or amend certain provisions in the Bidding Documents. This shall form an integral part of the Bidding Documents.

Main Concern and Clarifications:

The Opening of Sealed Bids for Lot D to Lot E shall be conducted on 9th July 2026. The opening schedule shall be as follows:

- **10:00 A.M. – Lot D to Lot E**

CLARIFICATION ON THE TECHNICAL SPECIFICATIONS SUPPLY, DELIVERY AND INSTALLATION, OF 69 KV LINE FOR PALAYAN CITY SUBSTATION: (LOT D)

This clarification is issued to amend and clarify the technical specifications for the Supply, Delivery and Installation, of 69 KV Line for Palayan City Substation (Lot D), as discussed during the Pre-Bid Conference held on 23 June 2026 at the NEECO II – Area 2 Main Office.

The following clarification shall form an integral part of the Bidding Documents and shall be considered by all prospective bidders in the preparation and submission of their bids.

Main Concern and Clarification:

1. Suspension Insulator

- The required suspension insulator shall be color gray.

2. Post Insulators

- All post insulators shall be 13-groove polymer type.

All other provisions of the Bidding Documents not affected by this Bid Bulletin shall remain in full force and effect.

JOCELYN S. PADERES
PBAC Chairman

